

TTH
TRANS TECH HANDELS-GMBH
A. d. Schleifmuehle 37
28203 Bremen – Germany

GUARANTEED TECHNICAL PARTICULARS
7.5 MVA 33/11 KV –Power Transformer-Off-Load

1.	Brand Name	TTH- Trans Tech Handels GmbH
2.	Services	Outdoor
3.	KVA Rating	
	(a) H.V. Winding	7500
	(b) L.V. Winding	7500
4.	Rated Voltage	
	(a) H. V. Winding	33000 Volts
	(b) L.V. Winding	11000 Volts
5.	Rated frequency	50 Hz
6.	Number of phases	Three
7.	Connection (a) H. V. Winding	Delta
	(b) L. V. Winding	Star
8.	Connections Symbol HV-LV	Dyn11
9.	Tapping (a)Range	+7.5% to – 7.5%
	(b) Number of steps	(Off circuit Tap changer) 6 steps of 2.5% each
	(c) For high voltage variation	Yes
10.	Max. Ambient air temp.	55°C
11.	Type of cooling	ONAN
12.	Temperature rise of	
	(a) Top oil by thermometer	50 °C
	(b) Winding by resistance	55°C

<p>TTH TRANS TECH HANDELS-GMBH A. d. Schleifmuehle 37 28203 Bremen – Germany</p>

GUARANTEED TECHNICAL PARTICULARS
7.5 MVA 33/11 KV –Power Transformer-Off-Load

13.	Total losses at rated voltage at principal tapping and rated frequency	57.5 KW
14.	Component losses	
	(a)No load loss at rated voltage at principal tapping and at rated frequency	7.5 KW
	(b)Load loss at rated current at principal tapping at 75° C	50 KW
15.	% Impedance voltage at rated current for the principal tapping H.V. – L.V.	8.35%
16.	Insulation level	
	a.Separate Source Power frequency voltage withstand	
	(i)H.V. Winding	70 KV rms
	(ii)L.V. Winding	28KV rms
	b.Induced over voltage withstand	
	(i)H.V.Winding	66 KV rms
	(ii)L.V.Winding	22 KVrms
	c.Full wave lightning impulse withstand voltage	
	(i) H.V. Winding	170 KV(P)
	(ii)L.V. Winding	75 KV(P)
17.	Terminal arrangement	
	(i) High Voltage	Outdoor bushings
	(ii) Low Voltage	Cable box bushings
18.	Reference standard	BS 171 & IEC 60076